

5102:1006
ISO 9001:2015



Scan the code with your smart phone
to verify the certificate

Certificate of Registration

This is to certify that the Quality Management System of
PARASMANI TUBES PVT. LTD.

5/2, GIDC, PHASE 1, UMBERGAON, VALSAD, GUJARAT-396171, INDIA

has been independently assessed by PQC and found to comply with the
requirements of

**(Quality Management System)
ISO 9001:2015**

For the following scope:

**MANUFACTURING AND SUPPLIERS OF COPPER TUBES,
FITTINGS AND INSULATION MATERIALS**

Certification Calendar:

Client Id: 10290

Certificate No: INQ/GUJ-11786/0822

Initial Registered Date: 08.08.2022

Issuance Date: 08.08.2022

Date of Expiry: 07.08.2025

1st Surv. Due: 07.08.2023

2nd Surv. Due: 07.08.2024



Authorized Signatory

PARAMOUNT QUALITY CERTIFICATIONS

27, Old Gloucester Street, London, WC1N 3AX, United Kingdom. Email: info@pqcert.in

Validity of this certificate is subject to successful completion of surveillance audit on or before of due date.
(In case surveillance audit is not allowed to be conducted, this certificate shall be suspended/withdrawal.)

Certification Verification: Please check this validity of the certificate at: <https://pqcert.in/certified-clients/> or www.pqcert.in at Certified Client
This Certificate remains the property of PQC & shall be returned immediately upon request.

PQC SCT PQC SCT PQC SCT PQC SCT PQC SCT PQC SCT PQC SCT PQC SCT PQC SCT

Certificate of Registration

This is to Certify that
Quality Management System of

M/S. PARASMANI TUBES PVT. LTD.

2A, D.S. KAPOLE NIWAS BUILDING, 4TH KHETWADI LANE,
MUMBAI - 400004, MAHARASHTRA, INDIA.

has been assessed and found to conform to the requirements of

ISO 9001:2008

for the following scope :


MANUFACTURING AND SUPPLIERS OF AIRCONDITIONING COPPER
TUBES, FITTINGS AND INSULATION MATERIALS.

Certification No	1015QDL97	
Initial Registration Date	: 26/12/2015	Issuance Date : 26/12/2015
Date of Expiry*	: 14/09/2018	
1st Surve. Due	: 26/11/2016	2nd Surve. Due : 26/11/2017
Note : Expiry Date shall be Extended to 25/12/2018 After Successful Transition of ISO 9001:2015		


Director



M4570910IN



JAS-ANZ



www.jas-anz.org/register

Absolute Quality Certification Pvt. Ltd.

Accredited By: Joint Accreditation System of Australia & New Zealand (JAS-ANZ)

401, Ashok Bhaswan, 93, Nehru Place, New Delhi - 110 019, | +91. 11. 4105 1139 | e-mail : info@absolutequalitycertification.com,

*Validity of the Certificate is subject to successful completion of surveillance audit on or before of due date. (In case surveillance audit is not allowed to be conducted, this certificate shall be suspended/withdrawn).

Certificate Verification: Please Re-check the validity of certificate at <http://www.absolutequalitycertification.com/activeclients.aspx> or
www.absolutequalitycertification.com at Active Clients.

Certificate is the property of Absolute Quality Certification Pvt. Ltd. and shall be returned immediately when demanded



Certificate of Registration

This certificate has been awarded to

Parasmani Tubes Pvt. Ltd.

5/2, G.I.D.C., Umbergaon, Valsad, Gujarat, 396171, India

in recognition of the organization's Quality Management System which complies with

ISO 9001:2008

The scope of activities covered by this certificate is defined below

Manufacture of Copper Tubes and Fittings for use in Air Conditioning and Refrigeration System

Certificate Number:

75822/C/0001/UK/En

Date of Issue: (Original)

19 November 2016

Date of Issue:

19 November 2016

Issue No:

1

Expiry Date:

14 September 2018

Issued by:

On behalf of the Schemes Manager





Certificate of Registration

This certificate has been awarded to

Parasmani Tubes Pvt. Ltd.

5/2, G.I.D.C., Umbergaon, Valsad, Gujarat, 396171, India

in recognition of the organization's Environmental Management System which complies with

ISO 14001:2004

The scope of activities covered by this certificate is defined below

Manufacture of Copper Tubes and Fittings for use in Air Conditioning and Refrigeration System

Certificate Number:

75822/B/0001/UK/En

Date of Issue: (Original)

17 November 2016

Date of Issue:

17 November 2016

Issue No:

1

Expiry Date:

14 September 2018

Issued by:

On behalf of the Schemes Manager





Certificate of Registration

This certificate has been awarded to

Parasmani Tubes Pvt. Ltd.

5/2, G.I.D.C., Umbergaon, Valsad, Gujarat, 396171, India

in recognition of the organization's Health and Safety Management System which complies with

OHSAS 18001:2007

The scope of activities covered by this certificate is defined below

Manufacture of Copper Tubes and Fittings for use in Air Conditioning and Refrigeration System

Certificate Number:

75822/A/0001/UK/En

Date of Issue: (Original)

16 November 2016

Date of Issue:

16 November 2016

Issue No:

1

Expiry Date:

15 November 2019

Issued by:

On behalf of the Schemes Manager



Chairman - Emeritus
VIRENDRA K. BAFNA
B. E. M. Eng. (Canada)
M.S.I.M. (U.S.A.) M. A. S. T. M.

TCR / QF 5101

Regd : Office & Laboratory
35, Pragati Industrial Estate,
N.M. Joshi Marg, Mumbai - 400 011.
Tel.: 23097921, 23097923,
23092347, 23091938
Fax: 91-22-23080197
Website : www.tcreng.com

Laboratory:
Plot No. EL - 182, M.I.D.C., TTC,
Electronic Zone, Mahape,
Navi Mumbai - 400 710.
Ph.: 022-67380900 / 9022137295
Fax: 2761 2044
Email : sales@tcreng.com



Certificate No. NABL-T-367,
NABL-T-368 & NABL-T-3304
NABL ISO 17025
ACCREDITED LABORATORY

ENGINEERING MATERIAL TESTING, CERTIFICATION, INSPECTION,
CONSULTING, SURVEYING, NDT SERVICES, HEAT TREATMENT,
PHYSICAL, CHEMICAL & METALLURGICAL TESTING.
APPROVED BY GOVT. OF INDIA - DEPT. OF SCIENCE & TECHNOLOGY
FOR CHEMICAL and MECHANICAL TESTING

TEST CERTIFICATE

TEST CERTIFICATE No:	BG/7191	Dated : 07.05.2016	Page No. 01 of 01
ISSUED TO:	PARASMANI TUBES PVT. LTD.. Mumbai - 400 004.		
TEST DATE:	07.05.2016		
TEST LOCATION:	TCR Engg. Services Pvt. Ltd., Mahape, Navi Mumbai.		
PARTY's REFERENCE:	Lt. Dt. 01.05.2016		
TEST METHOD :	With Reference to IEC - 62321/Ed 1.0/2008-12		
TEST INSTRUMENT:	PORTABLE XRF SPECTROMETER, MODEL INNOV - X Mfg By INNOV-X SYSTEMS EUROPE B V		
TEST PURPOSE:	TO SCREEN FOR R.O.H.S. DIRECTIVE 2011/65/EU REQUIREMENTS		

requirement	Hg	Br	Pb	Cr	Cd
Polymer Materials	$P \leq (700-3\delta) < X < (1300+3\delta) \geq F$	$P \leq (300-3\delta) < X$	$P \leq (700-3\delta) < X < (1300+3\delta) \geq F$	$P \leq (700-3\delta) < X$	$P \leq (70-3\delta) < (130+3\delta) \geq F$
Metallic Materials	$P \leq (700-3\delta) < X < (1300+3\delta) \geq F$	---	$P \leq (700-3\delta) < X < (1300+3\delta) \geq F$	$P \leq (700-3\delta) < X$	$P \leq (70-3\delta) < (130+3\delta) \geq F$
Electronics	$P \leq (500-3\delta) < X < (1500+3\delta) \geq F$	$P \leq (250-3\delta) < X$	$P \leq (500-3\delta) < X < (1500+3\delta) \geq F$	$P \leq (500-3\delta) < X$	$LOD < X < (250+3\delta) \geq F$

TEST FINDINGS

	Specified Elements	Hg	Br	Pb	CrVI	Cd	<u>REMARK</u>
	Item Description	← TEST REQUIREMENTS ----- Mg/Kg - (PPM) -----→					
		Max 1000	Max 1000	Max 1000	Max 1000	Max 100	
1	Copper Tube 15.88mm x 0.8mm Thk x 260mm Long	ND	ND	ND	ND	ND	Satisfactory

Remark: All Materials mentioned above are ROHS compliance in accordance with ROHS directive 2011/65/EU & It's subsequent amendments directives.

P = Pass F = Fail INC. = Inconclusive ND = Not Detected



Pm/-

For TCR ENGINEERING SERVICES PVT. LTD.

Authorized Signatory

- The results relate only to the sample tested.
- Test Certificate shall not be re-produced except in full without the written approval of laboratory.
- While 'TCR' has made their best endeavors to provide accurate and reliable information, 'TCR' is not responsible for any financial liability due to any act of omission or error made.
- NABL Cert No. T - 0367 - Chemical Testing, T - 0368 - Mechanical Testing, T-3304 - Non Destructive Testing.

A. P. INAMDAR (MGR. INT)

Chairman - Emeritus
VIRENDRA K. BAFNA
B. E. M. Eng. (Canada)
M.S.I.M. (U.S.A.) M. A. S. T. M.

TCR / QF 5101

Regd : Office & Laboratory
35, Pragati Industrial Estate,
N.M. Joshi Marg, Mumbai - 400 011.
Tel.: 23097921, 23097923,
23092347, 23091938
Fax: 91-22-23080197
Website : www.tcreng.com

Laboratory:
Plot No. EL - 182, M.I.D.C., TTC,
Electronic Zone, Mahape,
Navi Mumbai - 400 710.
Ph.: 022-67380900 / 9022137295
Fax: 2761 2044
Email : sales@tcreng.com



Certificate No. NABL-T-367,
NABL-T-368 & NABL-T-3304
NABL ISO 17025
ACCREDITED LABORATORY

ENGINEERING MATERIAL TESTING, CERTIFICATION, INSPECTION,
CONSULTING, SURVEYING, NDT SERVICES, HEAT TREATMENT,
PHYSICAL, CHEMICAL & METALLURGICAL TESTING.
APPROVED BY GOVT. OF INDIA - DEPT. OF SCIENCE & TECHNOLOGY
FOR CHEMICAL and MECHANICAL TESTING

TEST CERTIFICATE

Page 1 of 1

Date: 10-05-2016

T.C. No. BG7192

Issued To. PARASMANI TUBES PVT.LTD

2A,D.S Kapole Nivas Khetwadi 4th Lane Mumbai-400 004

Party Ref. : Nil Dt:01-05-2016

Nature of Sample : Copper Tube

Specification : ---

Sample Drawn By: Party

Condition of Sample : Cut Length

Sample Received on : 06-05-2016

Date of Completion : 10-05-2016

Test : Salt Spray

Size : 9.52 mm x 0.8 mm
Thk x 260 mm Long**Result****Requirement****SALT SPRAY TEST :**

Test Method : ASTM B111-2011

Test Solution 5% NaCl
Test Temp. °C 35°
Volume of Salt Solution Collected 24ml(in 16 hrs)
PH of the Solution 6.80
Specific Gravity (Solution Concentration) 1.030
Tested exposure Time (Hrs) 24
Observation Interval (Hrs) 24
Test started on 07/05/16 at 12.00 pm
Test completed on 08/05/16 at 12.00 pm
Observation : No corrosion Observed After 24hrs.

*****END OF REPORT*****

ak/-



h

Authorised Signatory

S. S. SHANBHAG (T.M.)

- 1) The results relate only to the sample tested.
- 2) Test Certificate shall not be re-produced except in full without the written approval of laboratory.
- 3) While 'TCR' has made their best endeavors to provide accurate and reliable information, 'TCR' is not responsible for any financial liability due to any act of omission or error made.
- 4) NABL Cert No. T - 0367 - Chemical Testing, T - 0368 - Mechanical Testing, T-3304 - Non Destructive Testing.